CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #:	PRRES20216390
Address:	1705 SW 27TH ST, LEES SUMMIT, MO 64082
Inspected On:	Tuesday, February 14, 2023
Inspected By:	Mitchell Schwarz
Expiration Date:	3/16/2023 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Pending	

Corrective Action Required:

Misc

1

-sod -splash blocks and sump pump discharge to extend 36" from foundation -check water meter at time of sod. (Ensure meter well flush height and meter depth in well 14"-18")