

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20222754
Address: 2217 NW KILLARNEY LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Tuesday, February 14, 2023

Corrective Action Required:

1 Misc

- sod
- splash blocks and sump pump discharge to extend 36" from foundation
- GFCI protected outlet for master bath jacuzzi tub
- outlet above outdoor fireplace to be secured and spark ring
- will check water meter depth and well grade at time of sod. Ensure 14-18" from meter top to well lid.

Comments: