

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20222876  
Address: 2121 NW OBRIEN RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mitchell Schwarz	Failed	Tuesday, February 14, 2023

Corrective Action Required:

1 Misc

- anchor bolts to be in the middle 1/3 of sill plate
- address exterior wall stud SE garage over notched for anchor bolt
- identify small circles on plans in garage and master closet
- seal penetrations in r/a joist space above bar area and family room
- address exterior wall studs notched for anchor bolts in basement E wall
- all anchor bolts to be in the middle 1/3 of sill plate in basement

**Comments:**