

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20213741  
Address: 2170 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	Robb Popp	Failed	Tuesday, February 14, 2023

Corrective Action Required:

1	Misc	-Install all grab bars in proper locations at both restrooms -Provide code compliant screen at fresh air duct -Install permanent sign at electrical room -Provide GFCIs at washer receptacles -Seal ceiling penetrations in storage garages -Complete canopy and exterior electrical -Cut exterior cleanout to grade -Install all permanent fencing, exit devices, occupant load signage etc- To be complete before TCO -Obtain health department approval for pool -Complete corrections for all other departments
---	------	--

**Comments:**