

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20215282

Address: 3655 NE AKIN DR, Unit:B, LEES SUMMIT, MO 640643655 NE AKIN DR, Unit:C, LEES SUMMIT, MO 640643655 NE AKIN DR, Unit:D, LEES SUMMIT, MO 640643655 NE AKIN DR, Unit:E, LEES SUMMIT, MO 640643655 NE AKIN DR, Unit:A, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Khanh Nguyen	Partial	Tuesday, February 14, 2023

Corrective Action Required:

1	Misc	Attic firewall-1st layer OK
---	------	-----------------------------

****Scott-I tried to communicate with the framers to remove all the wood blockings from the firewall until after the 2nd layer of fire rock. I think they understood me with just the "yes" and "no". You still want to check and make sure**

Comments: