## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #: PRCOM20220646 Address: 805 NE LAKEWOOD BLVD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection	:	Inspector:	Outcome:	Date:
Electrical S	Service Inspection	Khanh Nguyen	Failed	Tuesday, February 14, 2023
Corrective Action Required:				
1	Misc *	**HAVE ENGINEER SUBMIT PANEL LOAD PLAN WITH ALL INSTALLED		
	E	EQUIPMENTS. THE P1 SCHEDULE WILL NEED TO BE REVISED. PLAN NOT CALLS		
	F	FOR 400 AMP SERVICE. THIS WILL ALSO NEED TO BE REVISED.		

Comments: