

FIRE DEPARTMENT

Prevention Division (816)969-1300

PLAN REVIEW CONDITIONS

February 15, 2023

MIDWEST DIVISION LSH LLC PO BOX 80610, INDIANAPOLIS IN 46280 INDIANAPOLIS, IN 46280

Permit No:	PRCOM20230456
Project Title:	LEES SUMMIT MEDICAL CENTER - CHILLER PLANT REVISIONS
Project Address:	2100 SE BLUE PKWY, LEES SUMMIT, MO 64063
Parcel Number:	6042099090000000
Location:	HCA MIDWEST, LOTS 1A & 1BLOT 1A
Type of Work:	ALTERATION COMMERCIAL
Occupancy Group:	INSTITTIONAL, INCAPACITATED
Description:	CHILLER PLANT RENOVATIONS

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Development Services Department (816) 969-1200

Fire Department (816) 969-1300

Fire Plan Review	Reviewed By: Jim Eden	Approved with Conditions
	Refielded by: Jill Eden	Approved with conditions

1. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance testing.

The fire department shall witness testing of all safies, overides and interlocks at time of final inspection.

Building Plan Review

Reviewed By: Joe Frogge

Approved

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.