

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20213689  
Address: 1241 NE GOSHEN DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Khanh Nguyen	Failed	Thursday, February 16, 2023

Corrective Action Required:

1	Misc	-Underslab plumbing not inspected and approved
		-3 plant bushes required at rear per plot plan missing
		-Ground meter to rod
		-Provide secondary lock for the slide door per security code

**Comments:**