

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20222990  
Address: 2059 NW OBRIEN RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Control</b>	Robb Popp	Failed	Thursday, February 16, 2023

Corrective Action Required:

2	Miscellaneous Correction	DEFICIENT EROSION CONTROL INSTALLATION.  - MAINTAIN GRAVEL FILTER AT DRIVEWAY - 6" MIN LIFT OF 3/4" GRAVEL REQUIRED - MAINTAIN GUTTER BUDDY & REMOVE SILT DEPOSITS AT CURB INLET - -CLEAN DEBRIS FROM STREET
---	-----------------------------	---

**Comments:**