

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20214430
Address: 126 NW JOSHUA DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|---------------|----------|-----------------------------|
| Occupancy Inspection - Codes Residential | Shawn Hoffman | Failed | Thursday, February 16, 2023 |

Corrective Action Required:

| | | |
|---|-----------------------------|--|
| 1 | Miscellaneous Correction | Provide ledger bolts covered deck Joist hangers missing nails covered deck Provide (2) through bolts deck beam to post connection Address non continuous 6 x 6 post covered deck plan shows full height 6x6 cedar post on Simpson ABU66 post base [complete engineers recommended correction] |
|---|-----------------------------|--|

Comments: