

ANALYTICAL REPORT

February 16, 2023

Work Order: 1GB1394

Page 1 of 3

Report To
Ryan Heckman City of Lee's Summit - Public Works Dept. 220 SE Green Str Lees Summit, MO 64063

Work Order Information
Date Received: 02/15/2023 11:00AM Collector: Heckman, Ryan Phone: (816) 969-7428 PO Number: Routine Analysis

Project : Larry Bair Excavating

Project Number: Pergola Park 5th & Lumbermans Row

Analyte	Result	MRL	Batch	Method	Analyst	Analyzed	Qualifier
1GB1394-01 #1				Matrix:Drink Wtr		Collected: 02/15/23 09:23	
Total Coliforms	<1.0 MPN/100ml	1.0	1GB0717	9223B-QT	CLJ	02/15/23 16:15	
E. Coli	<1.0 MPN/100ml	1.0	1GB0717	9223B-QT	CLJ	02/15/23 16:15	
1GB1394-02 #2				Matrix:Drink Wtr		Collected: 02/15/23 09:26	
Total Coliforms	<1.0 MPN/100ml	1.0	1GB0717	9223B-QT	CLJ	02/15/23 16:15	
E. Coli	<1.0 MPN/100ml	1.0	1GB0717	9223B-QT	CLJ	02/15/23 16:15	
1GB1394-03 #3				Matrix:Drink Wtr		Collected: 02/15/23 09:28	
Total Coliforms	<1.0 MPN/100ml	1.0	1GB0717	9223B-QT	CLJ	02/15/23 16:15	
E. Coli	<1.0 MPN/100ml	1.0	1GB0717	9223B-QT	CLJ	02/15/23 16:15	
1GB1394-04 #4				Matrix:Drink Wtr		Collected: 02/15/23 09:32	
Total Coliforms	<1.0 MPN/100ml	1.0	1GB0717	9223B-QT	CLJ	02/15/23 16:15	
E. Coli	<1.0 MPN/100ml	1.0	1GB0717	9223B-QT	CLJ	02/15/23 16:15	
1GB1394-05 #5				Matrix:Drink Wtr		Collected: 02/15/23 09:34	
Total Coliforms	<1.0 MPN/100ml	1.0	1GB0717	9223B-QT	CLJ	02/15/23 16:15	
E. Coli	<1.0 MPN/100ml	1.0	1GB0717	9223B-QT	CLJ	02/15/23 16:15	
1GB1394-06 #6				Matrix:Drink Wtr		Collected: 02/15/23 09:37	
Total Coliforms	<1.0 MPN/100ml	1.0	1GB0717	9223B-QT	CLJ	02/15/23 16:15	
E. Coli	<1.0 MPN/100ml	1.0	1GB0717	9223B-QT	CLJ	02/15/23 16:15	

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. Samples were preserved in accordance with 40 CFR for pH adjustment unless otherwise noted. MRL= Method Reporting Limit.

City of Lee's Summit - Public Works Dept.
220 SE Green Str
Lees Summit, MO 64063

February 16, 2023

Work Order: 1GB1394

Page 2 of 3

Certified Analyses included in this Report

Method/Matrix	Analyte	Certifications
9223B-QT in Drink Wtr		
	Total Coliforms	KS-KC,MO-KC
	E. Coli	KS-KC,MO-KC

Code	Description	Number	Expires
KS-KC	Kansas Department of Health and Environment-KC	E-10110	04/30/2023
KS-NT	Kansas Department of Health and Environment (NELAP)	E-10287	10/31/2023
MO-KC	Missouri Department of Natural Resources	140	04/30/2023
SIA1X	Iowa Dept. of Natural Resources	95	02/01/2024

End of Report



Keystone Laboratories, Inc.

Carolyn Jackson
Project Manager

CHAIN OF CUSTODY RECORD



LABORATORIES, INC.

600 E. 17th St. S
Newton, IA. 50208
Phone: 641-792-8451

3012 Ansbrough Ave
Waterloo, IA. 50701
Phone: 319-235-4440

X 835 S St. Paul
Kansas City, KS. 66105
Phone: 913-321-7856

205 E Van Buren St
Centerville, IA. 52544
Phone: 641-437-7023

PRINT OR TYPE INFO BELOW:

SAMPLER: Ryan Heckman
SITE NAME: Pergola Park 5th and
Lumbermans Row
ADDRESS: 20221459
CITY/ST/ZIP: 20224162
PHONE:

REPORT TO:

NAME: Ryan Heckman
CO. NAME: City of Lee's Summit
ADDRESS: 220 SE Green St
CITY/ST/ZIP: Lee's Summit MO 64063
PHONE: 816-969-1224
Email: ryan.heckman@cityofs.net

BILL TO:

NAME: Troy Earring
CO. NAME: Larry Bair Excavation
ADDRESS:
CITY/ST/ZIP:
PHONE: 620-778-1982
Email: LAEE@BAIR-EXCAVATION.COM

CLIENT SAMPLE #	DATE	TIME	# OF CONTAINERS	MATRIX	GRAB/COMPOSITE	ANALYSES REQUIRED				LAB USE ONLY		
						Total Coliform				Wk-Order #:	16B1344	
#1	2-15-23	9:23 AM	1	DW	G	1				Short Hold:		
#2		9:26				1				Rush:		
#3		9:28				1				Temp. °C	br/hr	
#4		9:32				1				Sample Condition	Sample #	
#5		9:34				1					16B1344-01	
#6		9:37				1						

Relinquished by: (Signature) <i>[Signature]</i>	Date: 2-15-2023 Time: 9:45 AM	Received by: (Signature) <i>[Signature]</i>	Date: 2-15-23 Time: 9:45	Remarks:
Relinquished by: (Signature) <i>[Signature]</i>	Date: 2-15-23 Time: 10:43	Received for Lab by: (Signature) <i>[Signature]</i>	Date: 2/15/23 Time: 1045	

Turnin Heckman 02/15/23 @ 11:00