

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20220590  
Address: 520 NW CHIPMAN RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	Robb Popp	Failed	Friday, February 17, 2023

Corrective Action Required:

1	THE FOLLOWING AREAS ARE APPROVED	-Hard lids at bathrooms, kitchen and dining ok -Electrical room ok
---	----------------------------------	---

Corrective Action Required:

2	Misc	-Remove tile in kitchen and mechanical for inspection
---	------	---

**Comments:**