

From: [Greg Cox](#)
To: [Rhonda Saleski](#)
Cc: [Talby Twiford](#)
Subject: Fwd: 2808 Hearthstone place. HFR54
Date: Friday, February 17, 2023 11:43:19 AM

Can you please load this one too? Thank you

Greg Cox

Director Operations

SAB Construction, LLC

200 NW Commerce Court

Lee's Summit, MO 64086

[816-799-9110](tel:816-799-9110) Cell | [816-477-3454](tel:816-477-3454) Office Direct | [816-524-3855](tel:816-524-3855) Company

From: Dave Saunders <DASaunders@teagueelectric.com>

Sent: Tuesday, February 14, 2023 7:58:14 AM

To: Greg Cox <gregcox@sabhomes.com>

Cc: Justin McRoberts <JMcRoberts@teagueelectric.com>

Subject: 2808 Hearthstone place. HFR54

Greg,

On the installation of the Conduits for our electrical on the Patio at 2808 Hearthstone place In Lees Summit we have complied with the Minimum cover requirements table(300.5) This area is covered with concrete for non-vehicle use and we have stayed a minimum of 4" deep in a raceway to protect the circuits. In addition this area will be protected by GFCI devices or breakers.





Please let me know if you need anything else from me on this matter.

David Saunders

Residential Supervisor

Vice President

Teague Electric

 [913-529-4600](tel:913-529-4600) | [913-927-4087](tel:913-927-4087)
 dasaunders@teagueelectric.com
 www.teagueelectric.com
 12425 W. 92nd St, Lenexa, KS, 66215

