

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20222149
Address: 2808 SW HEARTHSTONE PL, LEES SUMMIT, MO 64082
Inspected On: Friday, February 17, 2023
Inspected By: Mitchell Schwarz
Expiration Date: 3/19/2023 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Pending	

Corrective Action Required:

- | | | |
|---|------|--|
| 1 | Misc | -sod-splash blocks and sump pump discharge to extend 36" from foundation
-bring water meter well to grade. Ensure 14"-18" from meter top to well lid ring
-label all non GFCI outlets in unfinished spaces |
|---|------|--|