

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20216183
Address: 2804 SW HEARTHSTONE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Friday, February 17, 2023

Corrective Action Required:

1	Misc	EROSION CONTROL TO REMAIN IN COMPLIANCE UNTIL SOD IN PLACE NO FURTHER INSPECTIONS UNTIL EROSION CONTROL IS IN COMPLIANCE -sod -splash blocks and sump pump discharge to extend 36" from foundation
---	------	---

Comments: