CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #:PRCOM20225294Address:5031 NE LAKEWOOD WAY, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:		Inspector:	Outcome:	Date:
Storm Sewer Construction Inspection		Patrick Schonfeldt	Partial	Tuesday, February 21, 2023
Informatio	onal:			
1	Misc	2-7-23 DP. Crew is starting to excavate and install HDPE for the rerouting of the existing storm. They are having problems by running into utilities that need to be moved. They found an unmarked water main that will need moved. The top of the new storm pipe will be flush at the top of the water main.		
		2-15-23 PS Contractor setting HDPE at existing public storm at NE side EX MH-1000. Corrugated storm being removed and replaced by HDPE. Collar has been poured at tie in to existing storm box.		
		2-17-23 PS Contractor Con towards 1000 MH. (1) stick	tinues to excavate and set H < of HDPE installed	HDPE at NE side working
			npleted pipe to and set man hole MH 1001. Contractor co ng pipe at 1001-1002	

Comments: