

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816) 969-1200 FAX (816) 969-1201

# Temporary Certificate of Occupancy

---

**Permit #:** PRRES20222754  
**Address:** 2217 NW KILLARNEY LN, LEES SUMMIT, MO 64081  
**Inspected On:** Wednesday, February 22, 2023  
**Inspected By:** Robb Popp  
**Expiration Date:** 3/24/2023 12:00:00 AM

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
-------------	------------	----------	-------

<b>Occupancy Inspection - Codes Residential</b>	Robb Popp	Pending	
---	-----------	---------	--

**Corrective Action Required:**

1	Misc	-sod -splash blocks and sump pump discharge to extend 36" from foundation -will check water meter depth and well grade at time of sod. Ensure 14-18" from meter top to well lid.
---	------	--