

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20215277

Address: 3671 NE AKIN DR, Unit:A, LEES SUMMIT, MO 640643671 NE AKIN DR, Unit:C, LEES SUMMIT, MO
640643671 NE AKIN DR, Unit:D, LEES SUMMIT, MO 640643671 NE AKIN DR, Unit:B, LEES
SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Khanh Nguyen	Failed	Thursday, February 23, 2023

Corrective Action Required:

1 Misc

UNIT C:

-Move b-vent min 1" from truss **still not corrected

Comments: