

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20214744
Address: 2119 NW KILLARNEY LN, LEES SUMMIT, MO 64081
Inspected On: Thursday, February 23, 2023
Inspected By: Robb Popp
Expiration Date: 3/25/2023 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Robb Popp	Pending	

Corrective Action Required:

- | | | |
|---|------|--|
| 1 | Misc | - Submit engineer approval of the retaining wall
-Final grade, sod, downspout and sump pump extension
-Provide sewer tracer wire port at grade
-Deck beam is not attached to each deck post with two 1/2" through bolts as required per code. Have engineer address |
|---|------|--|

Expiration of TCO 3/25/2023