

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20230211
Address: 1440 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Robb Popp	Failed	Friday, February 24, 2023

Corrective Action Required:

1	Misc	-Seal all penetrations -Remove metal stud and install layer of sheet rock at exposed steel per conversation -Complete rock at west end of wall both sides -Screw pattern at completed areas ok
---	------	---

Comments: