

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20230211
Address: 1440 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Commercial	Robb Popp	Failed	Friday, February 24, 2023

Corrective Action Required:

1	Miscellaneous Correction	-Provide pressure test of 5 psi or 10' water column -Properly bed drain in gravel at tie in -Clean out required at 90 degree change of direction
---	-----------------------------	--

Comments: