

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20224609  
Address: 508 SE CARTER RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Electrical Service Inspection</b>	Mitchell Schwarz	Not Ready	Friday, February 24, 2023

Corrective Action Required:

1	Misc	-Install a #4 copper jumper from the right EGC bus bar to the middle grounded bus bar. Currently #6 cu jumper is installed
---	------	--

**Comments:**