

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20222910
Address: 3107 SW SUMMIT VIEW TRL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Not Ready	Friday, February 24, 2023

Corrective Action Required:

1	Misc	-Missing nail in hanger at entry/master entry -fire block furr down ends and wall space into furr downs in basement (see basement shower wall)
---	------	---------------------------------------------------------------------------------------------------------------------------------------------------

Comments: