

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20220892

Address: 1052 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811054 NW BLACK TWIG CIR, LEES SUMMIT, MO
640811056 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811050 NW BLACK TWIG CIR,
LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Robb Popp	Partial	Friday, February 24, 2023

Corrective Action Required:

1	Misc	1050-ok 1052-vertical fireblocking 10' oc max, protect dryer duct 1054, 1056 not inspected
---	------	--

Comments: