

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20216257
Address: 3226 SW PERGOLA PARK DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Patrick Schonfeldt	Failed	Thursday, February 23, 2023

Informational:

1 Misc 2-2-2023 DP Crew has SW formed and aggregate places. Approved to pour

Corrective Action Required:

2 Miscellaneous Correction 2-9-23 DP. There are 2 panels by the stairs that are cracked and will need to be replaced before passing. Please call back in for an inspection before repouring.

02/21/23 Tuesday JMJ (Zach 816-853-2294)

Contractor removed 3 panels. Sidewalk - Pre-inspection forms and materials passed.

Corrective Action Required:

3 Misc 2-23-23 PS Slope on sidewalk is over 2% and does not meet ADA or LS requirements.

2-27-23 DP. There are 4 panels at this address that do not meet ADA compliance, They are marked with an "X". Need replaced. Call in for reinspection.

Comments: