

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20216257
Address: 3226 SW PERGOLA PARK DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Shawn Hoffman	Failed	Monday, February 27, 2023

Corrective Action Required:

1	Miscellaneous Correction	2-27-23 DP. Erosion control needs to be addressed at this address. Mud is across the street by the storm boxes, debris in throat of storm boxes and in neighbors yard.
---	--------------------------	--

Comments: