

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20224010
Address: 3509 SW MARKET ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Mitchell Schwarz	Failed	Monday, February 27, 2023

Corrective Action Required:

1	Misc	-signage for restrooms -mirror in restrooms -flush handle to be on accessible side in collection bathroom -outlets not working in ds collection area -side emergency exit door to be closing and opening properly -hardware installed on all doors -permanent label on gas meter
---	------	--

Comments: