

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20220893

Address: 1003 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811005 NW BLACK TWIG CIR, LEES SUMMIT, MO
640811007 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811001 NW BLACK TWIG CIR,
LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Robb Popp	Failed	Monday, February 27, 2023

Corrective Action Required:

1	Misc	-Complete final grade, sod, downspout extensions, foundation drainage -Provide access to rooftop for inspection -1007- repair drywall in rated assembly in garage storage
---	------	---

Comments: