

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20201955

Address: 3151 NW VIEW HIGH PKWY, LEES SUMMIT, MO 640813100 NW VIEW HIGH PKWY, LEES SUMMIT,
MO 640811401 NW RIVER RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|------------|----------|------------------------------|
| Underground Electrical Inspection - Commercial | Robb Popp | Partial | Tuesday, January 17, 2023 |

Informational:

1 Misc

09/12/22 Monday JMJ (Westhues Electric)

9 Underground conduit were installed 5 - 2" gray lines & 4 - 4" black lines (Electrical)

- 10/4/22 SE FIELD # 2 UNDERGROUND CONDUIT
FROM MIDDLE FIELD 1&2 TO MIDDLE FIELD 2&3 -

1/13/23

-4" Conduit for concession stand from SE corner of field 6 to center of field 6

1/17/23

-Conduit from center of 6 to SE corner of field 2

Comments: