

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20213741
Address: 2170 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Robb Popp	Failed	Tuesday, February 28, 2023

Corrective Action Required:

1	Misc	**OK to use workout room. Pool area to remain locked until Final Inspeccion is complete
		<ul style="list-style-type: none">-Complete pool-Install permanent sign at electrical room-Provide GFCIs at washer receptacles-Seal ceiling penetrations in storage garages-Complete exterior electrical at canopy-Cut exterior cleanout to grade-Install all permanent fencing, exit devices, occupant load signage etc-Obtain health department approval for pool-Complete corrections for all other departments

Comments: