

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20220892

Address: 1052 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081  
1054 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081  
1056 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081  
1050 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Commercial</b>	Robb Popp	Partial	Tuesday, February 28, 2023

Corrective Action Required:

1	Misc	1050-ok 1052-OK 1054-OK 1056-Provide anchor bolts and hold downs at garage sill plate, secure nm at service panel, seal top plate penetration at dwv in bath 2
---	------	---

**Comments:**