

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20220708
Address: 3204 SW SADDLEBRED TER, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Ryan Heckman	Partial	Wednesday, March 01, 2023

Informational:

1	Misc	2-27-23 RH. Subgrade was oversaturated and not solid due to the rain overnight. There was visible mud that needed removed. Contractor will clean up and call in tomorrow.
		3-1-23 RH. Sidewalk was formed up and aggregate is placed and compacted. Cross slope currently passes. Approved to pour.

Comments: