

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20220625
Address: 2018 SW RED BARN LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Wednesday, March 01, 2023

Corrective Action Required:

1 Misc

- provide attic access above garage(protect nm within 6' of attic access)
- address s3.2 10 strapping at deck (uncover at deck to show attachment)
- missing stud pack NE Breakfast area(3 jack studs)
- provide joist hangers for ceiling joists above master bath(missing nail)
- anchor bolts in basement to be in the middle 1/3 of sill plate and tight not completed
- Missing double floor joist above SE basement corner

Comments: