

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20221051
Address: 3218 SW ENOCH ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Wednesday, March 01, 2023

Corrective Action Required:

1 Misc

- address rear slider wall not framed to plans
Plans call for windows
- address bored through successive studs in master bath load bearing wall
- provide support for furr down to floor joists above
- anchor bolts to be in the middle 1/3 of sill plate in basement
- fire block vertically to horizontally every 10' in basement
- SW basement window to be cspf
- fire block NW basement bed wall to ceiling space
- fire block all furr down ends in basement
- complete cspf exterior nailing throughout

Comments: