

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20215829  
Address: 2051 SW HOOK FARM DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mitchell Schwarz	Not Ready	Wednesday, March 01, 2023

Corrective Action Required:

1	Misc	-provide attic accessible -address holes in joists above garage entry drilled closer than 2"(upload engineer letter for fix) sisters joist not to be over notched -address holes in floor joist drilled closer than 2" to edge of joist above laundry (upload engineer letter and fix to engineer specifications) -address rafter landing on blocks at master bed SE corner, and covered deck (provide engineering for fix )
---	------	---

Comments: