

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20224485  
Address: 1637 SW ARBORWAY TER, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Mitchell Schwarz	Failed	Thursday, March 02, 2023

Corrective Action Required:

1	Misc	-splash blocks and sump pump discharge to extend 36" from foundation -sod -will check water meter at time of sod ensure meter well to grade and meter in well 14"-18" from lid of meter to ring of well -will check all outlets in garage at Re-Inspection (power washing being performed -missing handrail in garage -outlets required for kitchen island -missing hand rail to basement -gypsum board underneath stair area in basement -
---	------	---

**Comments:**