

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20230414
Address: 4391 SW AMETHYST DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Thursday, March 02, 2023

Corrective Action Required:

1	Misc	-provide support for furr downs in garage to floor joist above -missing ceiling joist in furr down -provide vertical to horizontal fire blocking every 10' -fire block furr down ends -seal all top plate penetrations throughout
---	------	---

Comments: