

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20213548  
Address: 2100 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Miscellaneous Inspection</b>	Robb Popp	Failed	Thursday, March 02, 2023

Corrective Action Required:

1 Misc

Pre final for units only:

Throughout:

- Install enrtty doors and ensure doors self close and latch
- Secure mc under kitchen cabinets within 12" of boxes
- Install sprinkler escutcheons at exterior patios

Area A

- 337-throughout items
- 334-Tape seam in rated ceiling at mechanical closet
- 332-Bad GFCI at laundry
- 335-NOT READY
- 330-Bad GFCI at laundry, secure gaurdrail,seal rated assembly at ceiling in living room
- 333-throughout items
- 331-Secure gaurdrail
- 326-secure ac and seal penetration at hvac
- 324-throughout items
- 329-NOT READY

**Comments:**