



April 20, 2022

Pat Cochran Concrete

Re: 110 NW Ambersham Dr  
Lot 104, The Reserve at Woodside  
Lee's Summit Permit #:2021-5979

Apex Engineers, Inc. observed the preparation for the suspended garage slab at the above referenced address. Our firm was on site April 19<sup>th</sup> (12:30pm-1:30pm) and April 21<sup>st</sup>.

The garage slab will be suspended. The forms and reinforcing steel were found to be clean, well aligned, properly supported, and in general compliance with the on-site approved prints.

Note:

- At the time of the inspection the temperature was 55°.
- Erosion control needs repair at front of lot.

Our firm recommends approval of the suspended garage slab for the placement of concrete. This report does not constitute approval by the enforcing jurisdiction

---

#### LIMITATIONS

The recommendations and conclusions given in this report are based on the observed conditions at the time of this site visit. The scope of our services was only to observe the installation of the slab formwork and reinforcing steel.

Please call if Apex Engineers, Inc. can be of further assistance.

Best Regards,

A blue ink signature of Christopher Veith.

Christopher Veith  
*Senior Engineering Technician*

Clayton J. Hess, P.E.  
*Principal*

