

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20213548  
Address: 2100 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Miscellaneous Inspection</b>	Robb Popp	Partial	Monday, March 06, 2023

Corrective Action Required:

1 Misc

Pre final for units only:

Throughout:

-Install enrrty doors and ensure doors self close and latch

Area A

337-throughout items

334-throughout items

332-throughout items

335-throughout items, Provide box extensions and cover plates at kitchen and bath mirror, missing island recpetacle, missing covers at exterior exhaust, seal penetration at mechanical

330-throughout items,secure gaurdrail,seal rated assembly at ceiling in living room

333-throughout items

331-throughout items, Secure gaurdrail

326-throughout items

324-throughout items, complete exterior electrical

233-throughout item

234-anti tip device  
232-throughout item  
231-seal line sets  
230-secure gaurdrail  
228-breaker 14 bad  
229-seal line sets, escucheon at living  
227-anti tip  
224-throughout item

129-throughout items, hammer arrestor at dishwasher  
134-throughout item  
132-throughout item  
127-throughout items  
130-throughout item  
128-throughout item  
125-throughout item  
123-throughout items, seal penetrations, provide hand shower wand  
126-throughout items  
124-throughout items

**Comments:**