

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20216389
Address: 3230 SW PERGOLA PARK DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Devon Perry	Partial	Monday, March 06, 2023

Informational:
1 Misc 2-2-23 DP Crew had SW formed, aggregate placed and compacted. Approved to pour
2-9-23 DP Crew poured SW and it is in compliance. passed

Corrective Action Required:
2 Miscellaneous 2-27-23 DP. There are 3 panels that are not in ADA compliance. They are
Correction marked with an "X" the panels need to be replaced. Call back in for
reinspection.

Informational:
3 Misc 3-6-23 RH. Sidewalk is formed up and aggregate is placed and compacted.
Currently cross slope meets ADA specification. Approved to pour.

Comments: