

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20222561
Address: 1151 NE RICE RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Miscellaneous Inspection	Khanh Nguyen	Failed	Monday, March 06, 2023

Corrective Action Required:

1	Misc	**Fire department approval required -Secure downspouts to wall -Complete exterior wall finish -Secure CU raceway within 12" of disconnects -Provide addresses at front and back doors -Provide fire extinguishers per plan -Replace a non-working EM light at front exit (1159) -Point rear exit discharge light down (1155) -Provide access to electrical service grounding connections inside restroom wall
---	------	--

Comments: