

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20224091

Address: 540 NE TOWN CENTRE DR, LEES SUMMIT, MO 64064
520 NE TOWN CENTRE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|----------------------------------|-------------|----------|------------------------|
| Sanitary Sewer - Air Test | Devon Perry | Partial | Monday, March 06, 2023 |

Informational:

| | | |
|---|------|---|
| 1 | Misc | 3-6-23 DP. Air pressure test passed from MH A-1 to MH S-3 |
|---|------|---|

Comments: