



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20111762, Building Permit - Commercial

Address:

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Commercial	John Borns	Not Ready	Wednesday, May 18, 2011

Corrective Action Required

1 MISC

CABINET LOCKED. NO ACCESS FOR INSPECTION.

Corrective Action Required

2 MISC

ENSURE STREET ADDRESS NUMBER IS AFFIXED ON CABINET INTERIOR.

Final Electrical Inspection - Commercial	John Borns	Not Ready	Wednesday, May 18, 2011
---	------------	-----------	-------------------------

Electrical Service Inspection - Commercial	John Borns	Passed	Wednesday, May 18, 2011
---	------------	--------	-------------------------

Comments: RELEASE SERVICE. REQUEST RE-INSPECTION WHEN ADDRESS # IS AFFIXED TO PEDESTAL.