

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20223626
Address: 2762 SW 12TH ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Failed	Tuesday, March 07, 2023

Corrective Action Required:

1	Misc	<ul style="list-style-type: none">- GFCI at panel not protected not tripping and not wired correctly- FYI. Water on flooring behind basement bathroom possible leak- Seal upward penetrations in unfinished basement areas.- Final grading and sod- Splash blocks- Sump discharge minimum of 36" from foundation
---	------	---

Comments: