

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20220708
Address: 3204 SW SADDLEBRED TER, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Ryan Heckman	Passed	Tuesday, March 07, 2023

Informational:

1	Misc	2-21-23 RH. Forms are up and aggregate is placed and compacted. Approved to pour.
		3-7-23 RH. Driveway meets LS and ADA specification.

Comments: