

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20213548
Address: 2100 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Miscellaneous Inspection	Robb Popp	Partial	Tuesday, March 07, 2023

Corrective Action Required:

1	Misc	Pre final for units only, corridors, common spaces, stairwells, etc. not inspected:
---	------	---

Throughout:

-Install entry doors and ensure doors self close and latch

Area A

Units complete except throughout item and as noted:

335-Provide box extensions and cover plates at kitchen and bath mirror, missing island receptacle, missing covers at exterior exhaust, seal penetration at mechanical

330-secure gaurdrail, seal rated assembly at ceiling in living room

331-Secure gaurdrail

324-complete exterior electrical

231-seal line sets

230-secure gaurdrail

229-seal line sets, escutcheon at living room

123-seal penetrations, provide hand shower wand

Comments: