

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20223574  
Address: 2754 SW 12TH ST, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Shawn Hoffman	Failed	Tuesday, March 07, 2023

Corrective Action Required:

2	Miscellaneous Correction	<ul style="list-style-type: none"><li>- No overlap of top plate both sides of front entry wall</li><li>- Fb top plate hole in master toilet room</li><li>- Solid block sheeting breaks at bedroom 4</li><li>- Provide anchor bolts within 12" of plate breaks , multiple locations</li><li>- Solid block cantilevers in basement</li><li>- Address deck beam splice 2x12 glue lam to a double 2x10"??? Check deck plans</li><li>- Open entry sheeting for framing inspection</li></ul>
---	--------------------------	--

**Comments:**