

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20221526  
Address: 904 NW PRYOR RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                          | Inspector: | Outcome: | Date:                   |
|--------------------------------------|------------|----------|-------------------------|
| <b>Electrical Service Inspection</b> | Robb Popp  | Failed   | Tuesday, March 07, 2023 |

Corrective Action Required:

|   |      |   |
|---|------|---|
| 1 | Misc | --Label all services and disconnects-replace peeling label at house panel<br>-Bond all metallic parts-Conductor to be sized for entire 800 amp service<br>-Connect grounding conductors to service neutral per code |
|---|------|---|

**Comments:**