



Date: 03/08/2023
From: John Funk, PE
Subject: NLV Lot 31 – Roof Top Units
Address: 420 SW Longview Blvd, Lee's Summit, MO

Dear David,

Per your request, we have reviewed the roof framing for the anticipated RTU layout. Based on the M101 drawing dated 02/03/2023 as compared to our roof framing sheet S102, the roof structure is adequate for the loads and units shown. If the layout or weights of the units change, we would be happy to review the new condition.

If you have any questions regarding our findings, please let me know.

Sincerely,

John Funk, PE



John E. Funk
03/08/23